D-4	Weight 100lbs (HO) FF 70les (Metric)	Deathless CDDI CDT0411A 444	4
MicroMetl RTU:	Weight: 123lbs (US) 55.79kg (Metric)	Part Number: CRBK-SRT34HA-141	1
RTU:			
Submitted to:	Approved by:	Notes:	
Knockdown Structurally Calculated Curb - 14 Inches Tall Non Insulated Full Perimeter Knockdown Structurally Calculated Curb, California State Standard, High Seismic Criteria, Includes Hold-Down Brackets. "Structurally" Stamped By A Professional Engineer, Without Pitch, Insulated Deck Pan If Applicable, Includes Wood Nailer & Hold Down Brackets. Meets Seismic Requirements for 2022 CBC & 2021 IBC. Wind Design Criteria: 60 Foot Tall Building Maximum, Exposure C, 155 MPH - 3 Second Gust Speed, Risk Category III & IV.			
FORM NO.:	4 5	6 7	8
53.500 TOP O.D. 50.000 1.D.	40.063	1.813  CURB END DETAIL  KNOCK DOWN CURB	1.625  MICROHOLD DETAIL UNIT TO CURB
31.375 31.375 31.875 BOTTOM O.D.	SUPPLY	CORNER DETAIL  14 GA MICROHOLD TTACH TO CURB W/ TEK SCREWS SECURE TO UNIT W/ (3) #12x1-1/2 TEK SCREWS	ATTACHMENT DETAIL  TYP. UNIT  BASE RAIL  #12 TEK SCREW
SEISMIC DESIGN CRITERIA: -  p = 1.5 - Ss = 2.50 - Fa = 1.2  WIND DESIGN CRITERIA: - 60 FT. TALL BUILDING MAX EXPOSURE C - 155 MPH, 3-SECOND GUST WIND SPEED - RISK CATEGORY III & IV - (2) MICROHOLDS PER LONG SIDE - (3) MICROHOLDS PER SHORT SIDE  B THE STANDARD PRODUCT DOES NOT INCLUDE THROUGH THE SIDE SERVICE HOLES	BOTTOM O.D.  CUR	B ENDS AND SIDES ARE ATTACHED WITH TABS  16 GA CURB FRAME 16 GA CURB FRAME 16 GA CURB FRAME	MICROHOLD  WOOD NAILER  CURB
MicroMetl Corporation	CRBK-SRT34HA-08 Series 08" TALL 96 LBS. CRBK-SRT34HA-11 Series 11" TALL 110 LBS. CRBK-SRT34HA-14 Series 14" TALL 123 LBS.	STRUCTURALLY CALCULATED KNOCK DOWN CURB MAX UNIT WEIGHT 1786 lbs.	
ANCHORAGE DETAILS TO ROOF: AL DETAILS AND CONTROL OF THE PROPERTY OF THE PROPE	CURB CURB CURB CURB CURB CURB CURB CURB	CONCRETE ATTACHMENT:  COOK PST MINIMUM, 8" MINIMUM THICKNESS)  (4" MIN EDGE DISTANCE, 3:3/4" EMBEDDED)  (14) 112" SIMPSON TITEN HD  CENTERED DO IN CURB FLANGE,  8" MINIMUM SPACING  (2) EACH LONG SIDE  (1) EACH SHORT SIDE  (2) EACH CORNER  a = 3"  CURB  CURB  BEAM  4"	Mo. 2602 2 Explanation of California 7/6/23  BJG# 20220039
This Document Is The Property Of MicroMetl Corporation And Is Delivered Upon The Express Condition That The MicroMetl Reserves The Right To Discontinue, Or Change At Any Time, Specifications.		Master Revision 0001A	