
Hart&Cooley
install confidence

SUBMITTAL DRAWING

- MATERIAL:
  OUTER – .018 THICK, G–90 GALVANIZED STEEL
- INNER – .016 THICK, ALUMINUM



CAT. NO.	A I.D.	B O.D.	C
3RDH	3	3–1/2	5–15/16
4RDH	4	4–1/2	5–15/16
5RDH	5	5–1/2	5–15/16
6RDH	6	6–1/2	5–15/16
7RDH	7	8	8–7/16
8RDH	8	9	8–7/16
10RDH	10	11	8–7/16
12RDH	12	13	8–7/16

UL LISTED

JOB NAME: _____
LOCATION: _____
ARCHITECT: _____
ENGINEER: _____
CONTRACTOR: _____

SUBMITTED BY:

DATE: 1/29/99

SD–3114

Type B Gas Vent
Draft Hood Connector
RDH
3"– 12" Diameter

Hart & Cooley, Inc., 500 E. Eighth St., Holland, MI 49423 Telephone (616) 392–7855 Fax: 1–800–223–8461

© Hart & Cooley, Inc 2002