MicroMetl	Date:	Weight: 45lbs (US) 20.41kg (Metric)	Part Number: ECD-SRT12CB-DCDS
	RTU:		
Submitted to:		Approved by:	Notes:

Economizer - Genesis Ultra Low Leak Economizer, Vertical Orientation, Siemens POL224.00 Multiple Speed Electromechanical Controller, Adjustable Dry Bulb Sensor, Siemens Actuator. Painted Rain Hood With Aluminum Filter, Barometric Relief, All Necessary Panels And Hardware Included. For Differential Return Air Sensor Please Order KIT-3534-DIFFADB

FOR MODEL NUMBER: 48/50GC 04 - 06; 48/50FC 04 - 07; 48/50GCQ 04 - 06; 48/50FCQ 04 - 07

DETAILS: Model Details

(FOR 48/50 TC, TCQ 03 - 07; 48/50 HC, HCQ A04 - A06; 48/50LC, KC 04 - 06, HARNESS P/N 9962-2020 WILL NEED TO BE PURCHASED SEPARATELY)

****NOT FOR USE WITH 48/50JC 04-06 UNITS, PLEASE ORDER ECD-SRT12CB-D0DB-4****

FEATURES:


- External gear driven dampers with roll formed blades.
- Factory assembled rain hood, with aluminum water entrainment filters.
- Filter access door supplied with RTU.
- Hinged filter access door if required, sold separately.
  - MMC P/# for Chassis 1 - ECD-SRT1CA-HDOOR
  - MMC P/# for Chassis 2 - ECD-SRT2CA-HDOOR
- All harnesses and plugs needed are supplied.
- Economizer OA and Return dampers are AMCA Class 1A listed.
- Relief damper is AMCA listed.
- Motorized relief available, add -M to end of part number
  - Ex: ECD-SRT12CB-DCDS-M
- Economizer with smoke detector available, add -S to end of part number
  - Ex: ECD-SRT12CB-DCDS-S


-Control Types	
-DCDS	Siemens controller, actuator , adjustable drybulb controls
-DCES	Siemens controller, actuator, enthalpy controls

* For Differential Sensors, please purchase Kit below:

Differential Dry Bulb Kit - KIT-3534-DIFFADB

Differential Enthalpy Kit - KIT-3534-DIFFENT





NOTE: The Siemens POL224.00 controller can be programmed using the buttons and the LCD display on the face of the controller or by using with Siemens app which can be found by searching "Climatix "in the app store and requires a Siemens WLAN Stick (Purchased separately - Siemens # POL903.00 or MicroMetl # 9901-5057).
The WLAN stick can be removed after programming and then re-used on other units /controllers. The app and WLAN Stick will allow for easier setup using GPS for automatic parameter setting by climate zone. Contact MicroMetl for the complete Siemens POL224.00 Application Guide.
The Controller is field mounted in the RTU control box.

Compliant Economizer:

1. **Title 24:** Economizers meet California Energy Commission Title 24-2016 / 2019 prescriptive section 140.4 (damper leakage etc.), and mandatory section 120.2.i for Fault Detection and Diagnostic controls.
2. **ASHRAE 90.1:** Economizers meet ASHRAE 90.1-2019 damper leakage requirements as stated in Table 6.4.3.4.3., and meet 2019 Fault Detection and Diagnosis requirements in section 6.4.3.12.
3. **IECC:** Economizers meet IECC 2018 section C402.4.5.2 and, IECC 2018 sections C403.2.4.3 and C403.3.3.5 for outside air, return air, and relief damper (when provided) leakage requirements, and IECC 2018 section c403.2.4.7 for Fault Detection and Diagnostic requirements.
4. **AMCA:** Outside air and return air (volume) dampers are AMCA Class 1A rated at 1" w.g. Refer to MicroMetl NS2 catalog sheet on web site for details.
   Relief air dampers are also AMCA rated. Refer to GR1 series catalog sheet on web site for details.

NOTES: SPECIAL NOTES

Openings and dimensions may vary from contract. An order constitutes acceptance of these variances.

This Document Is The Property Of MicroMetl Corporation And Is Delivered Upon The Express Condition That The Contents Will Not Be Disclosed Or Used Without MicroMetl's Written Consent. MicroMetl Reserves The Right To Discontinue, Or Change At Any Time, Specifications & Designs Without Any Notice Incurring Obligations.

Master Revision 0001A

Page Revision 0001A