

Indianapolis_3035 N. Shadeland Ave., Indianapolis, IN 46226_800.MMC.HVAC •• Sparks_905 Southern Way, Sparks, NV 89431_800.884.4MMC •• Longview_201 Kodak Blvd., Longview, TX 75602_903.248.4800

MiereMet	Date:	Weight:	74lbs	(US)	33.57kg	(Metric)	Part Number:	ECH-SRT12CB-D00B
SMicroMetl	RTU:							

Submitted to:		Approved by:	Notes:						
Sensor,			Only for 3rd Party Economizer Controls - No Controller, No ary Panels And Hardware Included. Must Field Provide 2-10 VDC						
Con	npliant Economizer:								
1.	1. Title 24: Economizers meet California Energy Commission Title 24-2013 / 2016 prescriptive section 140.4 (damper leakage etc.), and mandatory section 120.2.i								
	for Fault Detection and Diagnostic controls. 5 Year Warranty for parts and components only.								
	Diagnosis requirements in section 6.4.3.12.	4.5.2 and JECC 2015 sections C403.2.4.3	and C403.3.3.5 for outside air, return air, and relief damper (when						
1	provided) leakage requirements, and IECC 2015 se	ction c403.2.4.7 for Fault Detection and Dia	agnostic requirements, Note: IECC 2015 section C403.2.4.7.1 be ordered separately on others (i.eDYDB, -DYEB).						
4.		s are AMCA Class 1A rated 1" w.g. Refer to	MicroMetl NS2 catalog sheet on web site for details. Relief air						
		a duan thuan an D/A damanan in in aha	a mana						

Approximate static pressure drop through R/A damper in inches w.g.							
CFM	750	1400	1630	1850	2000	2400	
Pressure Drop	0.03	0.12	0.17	0.23	0.27	0.38	



MicroMetl Corporation certifies that the models GR1 and NS2 shown herein are licensed to bear the AMCA Seal. The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 511 and comply with requirements of the AMCA Certified Ratings Programs. The AMCA Certified Ratings Seal applies to Air Leakage and Air Performance ratings.

This Document Is The Property Of MicroMetl Corporation And Is Delivered Upon The Express Condition That The Contents Will Not Be Disclosed Or Used Without MicroMetl's Written Consent.	Master Revision 0001A
MicroMetl Reserves The Right To Discontinue, Or Change At Any Time, Specifications & Designs Without Any Notice Incurring Obligations.	Page Revision 0001A

Indianapolis_3035 N. Shadeland Ave., Indianapolis, IN 46226_800.MMC.HVAC •• Sparks_905 Southern Way, Sparks, NV 89431_800.884.4MMC •• Longview_201 Kodak Blvd., Longview, TX 75602_903.248.4800